



## Outsulation® SMD System™

## Termination at Roof to Wall Flashing

### NOTE:

1. EXTEND KICKOUT A MINIMUM OF 25 MM (1") BEYOND FACE OF SYSTEM.
2. KICKOUT DIVERTER TO BE MADE FROM CORROSION RESISTANT MATERIAL MIN. 24 GAGE.
3. EXTEND ROOFING PAPER 127 MM (5") MIN. UP VERTICAL WALL BEHIND METAL FLASHING.
4. METAL FLASHINGS ARE 254 MM (10") X 51 MM (2") LONGER THAN THE EXPOSED PORTION OF THE ROOFING SHINGLE AND ARE BENT IN HALF TO ALLOW FOR TWO 127 MM (5") LEGS. ALTHOUGH NOT SHOWN, METAL FLASHINGS ARE STEP FLASHED (INTERWOVEN) WITH ROOFING SHINGLES.

The architecture, engineering and design of the project using the Dryvit products is the responsibility of the project's design professional. All systems must comply with local building codes and standards. This detail is for general information and guidance only and Dryvit specifically disclaims any liability for the use of this detail and for the architecture, design, engineering or workmanship of any project. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent alternative is best suited for the project. Use of a functionally equivalent detail does not violate Dryvit's warranty. This detail is subject to change without notice. Contact Dryvit to insure you have the most recent version.

APPROVED BY:	REV:	DATE:
RS	4	02/09

