



NOTE:

1. MANUFACTURED STONE MASONRY VENEER UNITS SHALL BE RECOGNIZED IN A CURRENT ICC-ES EVALUATION REPORT DEMONSTRATING COMPLIANCE WITH ICC-ES AC51 ACCEPTANCE CRITERIA FOR ADHERED MANUFACTURED STONE MASONRY AND ASTM C1670 STANDARD SPECIFICATION FOR ADHERED MANUFACTURED STONE MASONRY UNITS. THIN VENEER BRICK SHALL DEMONSTRATE COMPLIANCE WITH ASTM C1088. THE AVERAGE SATURATED VENEER AND MORTAR WEIGHT COMBINED SHALL NOT EXCEED 15 POUNDS PER SQUARE FOOT.

2. PREPARE, MIX, APPLY AND INSTALL IN STRICT ACCORDANCE WITH OMVS APPLICATION INSTRUCTIONS DS976.

3. THE SUBSTRATE SHALL BE FREE OF PROJECTIONS AND SHALL BE FLAT WITHIN 1/4" IN A 4' RADIUS.

4. WALL ASSEMBLY SHALL PROVIDE FOR A MAXIMUM DESIGN DEFLECTION OF L/360.

This detail is for general informational purposes, only. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project with respect to any architecture, engineering, and design requirements, including any local building code requirements. If this document is not reviewed and the product is not approved for use by a licensed design professional, the customer agrees that the detail may contain substantive flaws requiring correction, and hereby releases Tremco CPG Inc. from any and all liability related to the design and installation of the product. This detail is subject to change without notice. Contact Tremco to ensure you have the most recent version.

Outsulation® Masonry Veneer System



Dryvit Technical Support: 800-556-7752

Detail: Dryvit Outsulation Masonry Veneer System

Drawn by: KAB

Checked by: CB/CW

Scale: NTS

Date: 3/2025

File Name:

OMVS 1



Construction Products Group

www.tremcocpg.com