



#### NOTES:

1. DRYVIT RECOMMENDS THAT GROUND FLOOR APPLICATIONS AND ALL FACADES EXPOSED TO ABNORMAL STRESS, HIGH TRAFFIC, OR DELIBERATE IMPACT HAVE THE BASE COAT REINFORCED WITH PANZER® MESH PRIOR TO STANDARD OR STANDARD PLUS MESH. LOCATION OF HIGH IMPACT ZONES SHOULD BE INDICATED ON CONTRACT DRAWINGS.
2. APPLY DYMONIC 100 AT 40 MILS 1" (25 MM) MIN. ONTO FACE OF SECUROCK EXOAIR 430 PANEL AND 1-5/8" (41 MM) INTO ROUGH OPENING OR PAST PRIMARY SEAL OF WINDOW, WHICHEVER IS GREATER.
3. COORDINATE WITH WINDOW SHOP DRAWINGS FOR TERMINATION OF FINISH.
4. INSTALL WINDOW UNIT AND ASSOCIATED FLASHINGS PER MANUFACTURER'S RECOMMENDATIONS, CODE REQUIREMENTS AND PROJECT DOCUMENTS.
5. INSULATION BOARD TO BE MINIMUM 3/4" (19 MM).
6. WEEP TUBE DESIGN PER SPECIFICATION, AS APPLICABLE.
7. LIGHTLY SAND SURFACE OF J-TRACK TO MAXIMIZE ADHESION.
8. LENGTH OF TRACK NOT TO EXCEED 10 FT (3.0 M)

*This detail is for general informational purposes only. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project with respect to any architecture, engineering, and design requirements, including any local building code requirements. If this document is not reviewed and the product is not approved for use by a licensed design professional, the customer agrees that the detail may contain substantive flaws requiring correction, and hereby releases Tremco CPG Inc. and USG from any and all liability related to the design and installation of the product. This detail is subject to change without notice. Contact Tremco and USG to ensure you have the most recent version.*

#### Outsulite® Securock® ExoAir® 430 Panel System

**USG** **TREMCO**  
SECUROCK® EXOAIR® 430

Technical Support: 866-209-2404

Detail: Head Drainage Options - Shop Installed Window

Drawn by: KAB

Checked by: AL

Scale: NTS

Revision #: 0

Revised by: NA

Date: 5/5/2025

[www.tremcocpg.com](http://www.tremcocpg.com)

File Name:

OSL D SE430  
10MD

**TREMCO**  
Construction Products Group